Module	Article number	As of firmware version
AI 4xU/I 2-wire ST*	6ES7134-6HD00-0BA1	-
AI 4xRTD/TC 2-/3-/4-wire HF	6ES7134-6JD00-0CA1	V2.1.1
AI 4xTC HS	6ES7134-6JD00-0DA1	V1.0.3
AI 8xRTD/TC 2-wire HF	6ES7134-6JF00-0CA1	V2.1.1
AI Energy Meter*	6ES7134-6PA00-0BD0	-
AI Energy Meter 400VAC ST*	6ES7134-6PA01-0BD0	-
AI Energy Meter 480VAC ST*	6ES7134-6PA20-0BD0	-
AI Energy Meter 480VAC HF*	6ES7134-6PAx0-0CU0	-
AI4 x I HART	6ES7134-6TD00-0CA1	V1.1.1
AQ 2xU/I HF	6ES7135-6HB00-0CA1	V1.0.3
AQ 2xU/I HS	6ES7135-6HB00-0DA1	V2.0.4
AQ 4xU/I ST	6ES7135-6HD00-0BA1	V1.1.3
AQ 4xI HART	6ES7135-6TD00-0CA1	V1.0.1
F-AI 4xI	6ES7136-6AA00-0CA1	V1.0.2
F-AI 4xU	6ES7136-6AB00-0CA1	V1.0.1
F-DI 8X24VDC HF	6ES7136-6BA00-0CA0	V1.0.7
F-DI 8X24VDC HF	6ES7136-6BA01-0CA0	V1.0.0
F-TM Count sin/cos 1x1Vpp HF	6ES7136-6CB00-0CA0	V1.0.0
F-DQ 4XDC 24V/2A	6ES7136-6DB00-0CA0	V2.0.2
F-DQ 8X 24VDC/0.5A PP	6ES7136-6DC00-0CA0	V1.0.1
F-PM-E PPM, 24V DC	6ES7136-6PA00-0BC0	-
CM PtP*	6ES7137-6AA00-0BA0	-
CM PtP	6ES7137-6AA01-0BA0	V2.0.0
CM 4xIO-Link	6ES7137-6BD00-0BA0	V2.2.2
CM DALI	6ES7137-6CA00-0BU0	V1.0.1
CM 1xCAN	6ES7137-6EA00-0BA0	V1.2
TM Count 1x24V*	6ES7138-6AA00-0BA0	-
TM Count 1x24V	6ES7138-6AA01-0BA0	V2.0.2
TM PosInput 1*	6ES7138-6BA00-0BA0	-
TM PosInput 1	6ES7138-6BA01-0BA0	V2.0.1
TM Timer DIDQ 10x24V	6ES7138-6CG00-0BA0	V1.0.3
TM Pulse 2x24V	6ES7138-6DB00-0BB1	V1.0.2
TM ECC 2xPWM 12V ST*	6FE1242-6TM10-0BB1	-
AI 2x SG 4-/6-wire HS (DMS)	7MH4134-6LB00-0DA0	V1.0.2
SIWAREX WP321	7MH4138-6AA00-0BA0	V1.4.4

* No firmware update is offered for these modules since there are compatible successor products

** No firmware update with the error correction is currently offered for these modules

I/O module		Article number	Firmware version	STEP 7 (TIA Portal)	STEP 7 V5.5 SP3
Digital output modules	DQ 4x24VDC/2A HS	6ES7132-6BD20-0DA0	V1.0.2	Integrated as of V14	HSP0230 V5.0
	DQ 4x24...230VAC/2A ST	6ES7132-6FD00-0BB1	V1.0	as of V13	HSP0230 V3.0
	DQ 4x24...230VAC/2A HF	6ES7132-6FD00-0CU0	V1.0.0	as of V14 with HSP0240	HSP 0230 as of V8.0
	RQ 4x120VDC-230VAC/-5A NO ST	6ES7132-6HD00-0BB1	V1.0.0	HSP0128	HSP0232 V5.0
	RQ 4x120VDC-230VAC/-5A NO MA ST	6ES7132-6MD00-0BB1	V1.0.0	HSP0162 V13 SP1 or higher	HSP0232 V6.0
Analog input modules	AI 8xU BA	6ES7134-6FF00-0AA1	V1.0.0	HSP0126	HSP0227 V5.0
	AI 2xU ST	6ES7134-6FB00-0BA1	V1.0.0	HSP0160 V13 SP1 or higher	HSP0227 V6.0
	AI 8xI 2-/4-wire BA	6ES7134-6GF000AA1	V1.0.0	HSP0126	HSP0227 V5.0
	AI 4xI 2-/4-wire ST	6ES7134-6GD00-0BA1	V1.1.0	V13 Update 3	HSP0227 V4.0
	AI 2xI 2-/4-wire ST	6ES7134-6GB00-0BA1	V1.0.0	HSP0160 V13 SP1 or higher	HSP0227 V6.0
	AI 4xU/I 2-wire ST	6ES7134-6HD00-0BA1	V1.1.0	V13 Update 3	HSP0227 V4.0
	AI 2xU/I 2-/4-wire HF	6ES7134-6HB00-0CA1	V2.0.0	HSP0161 V13 SP1 or higher	HSP0227 V6.0 V5.5 SP4 HF7 or higher
	AI 2xU/I 2-/4-wire HS	6ES7134-6HB00-0DA1	V2.0.1	Integrated as of V14	HSP0227 V5.0
	AI Energy Meter 400VAC ST	6ES7134-6PA01-0BD0	V3.0.0	V13 SP1 Update 4 HSP0159	HSP0227 V6.0
	AI Energy Meter 480VAC ST	6ES7134-6PA20-0BD0	V4.0.0	V13 SP1 Update 4 HSP0159	HSP0227 V6.0 V5.5 SP4 HF7 or higher
	AI Energy Meter 480VAC/CT HF	6ES7134-6PA00-0CU0	V6.0.0	V15 or higher with HSP0253	V5.5 SP3 or higher
	AI Energy Meter 480VAC/RC HF	6ES7134-6PA20-0CU0	V6.0.0	V15 or higher with HSP0253	V5.5 SP3 or higher
Analog output modules	AQ 2xU ST	6ES7135-6FB00-0BA1	V1.0.0	HSP0160 V13 SP1 or higher	HSP0228 V6.0
	AQ 2xI ST	6ES7135-6GB00-0BA1	V1.0.0	HSP0160 V13 SP1 or higher	HSP0228 V6.0
	AQ 4xU/I ST	6ES7135-6HD00-0BA1	V1.1.0	V13 Update 3	HSP0228 V4.0
	AQ 2xU/I HS	6ES7135-6HB00-0DA1	V2.0.1	Integrated as of V14	HSP0228 V5.0